

## **EC DECLARATION OF CONFORMITY**

The manufacturer **LAE electronic SrI**, registered offices at via Padova, 25 Oderzo ITALY, on the basis of the test results obtained using appropriate standards, states that the following product:

Name: thermometer

Model(s): LT6C(.)(.); LT6F(.)(.)

Version(s): ...P, T; ...D, I

meets the essential requirements provided by:

## Low Voltage Directive EEC 73/23 - 93/68 EMC Directive EEC 89/336 - 93/68 - 93/97

Standards and levels used:

EN60730-1; EN60730-2-9

EN50081-1:

Emissions EN55022 class B

EN50082-1:

Electrostatic Discharge EN61000-4-2 / IEC1000-4-2 - LEVEL IV RF EM Field EN61000-4-3 / IEC1000-4-3 - LEVEL III Fast Transients EN61000-4-4 / IEC1000-4-4 - LEVEL IV - LEVEL III Surges EN61000-4-5 / IEC1000-4-5 RF Common Mode EN61000-4-6 / IEC1000-4-6 - LEVEL III Voltage Dips/Interruptions EN61000-4-11 / IEC1000-4-11

Oderzo, 23/11/2001

Franco Perissinotto
Test Department